



**Jim Doyle, Governor**  
**Jack L. Fischer, A.I.A., Secretary**

January 22, 2008

FREY-MOSS STRUCTURES INC  
ED DUGAN  
1801 ROCKDALE IND BLVD  
CONYERS GA 30012

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: FREY-MOSS STRUCTURES INC  
Product Name: C-STORE  
Model Number(s): G7-B-0020  
Product File No: 20080021

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 50 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wi.gov